



ZHEJIANG YONGHE REFRIGERANT CO.,LTD.

SPECIALLY FOR



Product: HFC-134a

Batch No.: 1-1910301

Standard: GB/T18826-2016

The date of report: Oct. 31st, 2019

Items	Unit	Index	Inspection Results
Appearance		Colorless and no turbid	Qualified
Odor		No strange stench	Qualified
Purity	% (>)	99.90	99.92
Moisture	% (≤)	0.0010	0.0009
Acidity	(as HCL) %	≤0.0001	<0.0001
Vapor Residue	% (≤)	0.005	<0.005
Non condensable gases	% (≤)	1.5	1.4
Conclusion	QUALIFIED		
Remark	浙江永和制冷股份有限公司 TWDA080/YH1901 ZHEJIANG YONGHE REFRIGERANT CO.,LTD.		

Inspector: Xu Jianfu

Review: Liu Wangxing

Check: Ke Xuemei